


OPTION 1



OPTION 2

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
3. SPUD GRAVEL SURFACES A MINIMUM OF 14" WIDE PRIOR TO JM COATING INSTALLATION.
4. JM COATING FLASHING CONSISTS OF JM COATING UNIVERSAL BASE, JM COATING POLYESTER REINFORCING FABRIC AND JM COATING ACRYLIC FLASHING.
5. FOR JM COATING ACRYLIC FIELD SYSTEM 5 AND 10 YEAR GUARANTEE TERMS, USE THE APPROPRIATE APPLICATION REQUIREMENTS. REFER TO JM COATING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.

DRAWING NO.

CA-TI-01

ROOF SPLIT REPAIR (UP TO 1/4" WIDE)

MEMBRANE TYPE:
JM COATING - ACRYLIC

MAXIMUM GUARANTEE TERM:

SCALE
N.T.S

ISSUE DATE
01-23-19

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

