



NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION. PLEASE SEE BITUMINOUS FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
2. ANY CARPENTRY, METAL WORK, OR MASONRY CONSTRUCTION SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
3. SEAL SEAMS OF ROOF JACK.
4. DISTANCE BETWEEN TOP OF ROOF JACK AND VENT STACK SHOULD BE A MINIMUM OF 1".
5. THE TAPERED EDGE STRIP IS OPTIONAL. THE NAILERS AND ROOF SUBSTRATE MUST BE FLUSH.
6. FLASHING ROOF JACK WITH A TARGET PATCH OVER CAP SHEET IS ACCEPTABLE. SEE DFE-9 FOR TYPICAL FLASHING INSTALLATION.

| | | | | |
|--|----------------------|--------------------------|--|------------------------------|
| DRAWING NO. DFE-23 | | VENT STACK (WARM) | | <p>Johns Manville</p> |
| DRAINS & VENTS | | MEMBRANE TYPE: BUR | | |
| SCALE N.T.S | ISSUE DATE 1-2-15 | MAXIMUM GUARANTEE TERM: | | |
| <small>Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.</small> | | | | |