



ISOMETRIC VIEW

THOROUGHLY CLEAN METAL SCUPPER SLEEVE AND APPLY JM PMMA METAL PRIMER PRIOR TO INSTALLATION OF JM PMMA MEMBRANE FLASHING

SCUPPER SIZED BY LICENSED DESIGN PROFESSIONAL RE: NOTE 3

- JM PMMA MEMBRANE TARGET PATCH OVER SCUPPER OPENING
- PREPARE, LEVEL & PATCH SUBSTRATE WITH JM PMMA REPAIR PASTE AFTER PRIMING & PRIOR TO INSTALLATION OF JM PMMA MEMBRANE
- JM PMMA MEMBRANE 2" MIN. OVERLAP PROVIDING CONTINUOUS FLASHING
- JM PMMA MEMBRANE FLASHING EXTENDED THROUGH TO THE OUTSIDE OF SCUPPER OPENING AND OVERLAP 2" TO FORM SCUPPER FLASHING
- ENSURE FULL RESIN SATURATION OF JM PMMA SCRIM AND CONTACT WITH SUBSTRATE
- ENSURE ALL MEMBRANE TERMINATIONS ARE ENCAPSULATED IN JM PMMA RESIN
- BITUMINOUS FIELD MEMBRANE

USE THIS DETAIL IN CONJUNCTION WITH DETAIL LB-DV-02S WHICH IS PART OF THIS INSTALLATION.

- NOTES:**
1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
 2. PLEASE SEE JM PMMA FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
 3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
 4. JM PMMA MEMBRANE FLASHING CONSISTS OF JM PMMA STANDARD RESIN, JM PMMA SCRIM, JM PMMA STANDARD RESIN.
 5. ALL SEALANTS / CAULKING SHALL BE PERIODICALLY INSPECTED AND MAINTAINED BY THE BUILDING OWNER THROUGHOUT THE LIFE OF THE ROOF.

JM PMMA THROUGHWALL SCUPPER FLASHING

DRAWING NO. LB-DV-02 NEW DETAIL	MEMBRANE TYPE: JM PMMA OVER BITUMINOUS	ISSUE DATE 6-18-18
	MAXIMUM GUARANTEE TERM: 20 YEAR	SCALE N.T.S

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

