



NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL. CONTACT JM TECHNICAL FOR METAL OPTIONS TO BE INCLUDED WITHIN THE JM NDL GUARANTEE.
4. OVERLAP ADJOINING EPDM MEMBRANES AT ALL LOCATIONS A MINIMUM OF 3" (AND UP TO 6" DEPENDING ON SPECIFICATION/GUARANTEE). EPDM SEAM TAPE IS USED TO SEAM EPDM MEMBRANE LAPS. JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC) MUST BE APPLIED ON ALL SURFACES COMING INTO CONTACT WITH JM EPDM PEEL & STICK PRODUCTS.
5. FOR JM APPROVED BASE FLASHING FASTENING METHODS SEE E-FW-B DETAILS.

6" X 6" EPDM PEEL & STICK FLASHING REQUIRED AT TRANSITION SEAMING

NOTES CONTINUED:

6. FOR JM APPROVED INTERMEDIATE FLASHING FASTENING METHODS SEE E-FW-I DETAILS. MINIMUM FLASHING TERMINATION HEIGHT IS 8" (203 mm) ABOVE ROOF SURFACE ON ANY JM APPROVED SUBSTRATE, IE. PLYWOOD, SECUROCK® GYPSUM-FIBER, AND DENSDECK®.
7. FOR JM APPROVED TOP OF WALL FLASHING METHODS SEE E-FW-T DETAILS.
8. JM APPROVED ADHESIVES FOR USE ON VERTICAL FLASHING APPLICATIONS INCLUDES JM LVOC MEMBRANE ADHESIVE (TPO & EPDM) AND JM MEMBRANE BONDING ADHESIVE (TPO & EPDM) ONLY.
9. ON RE-ROOFING PROJECTS, AN APPROVED ASPHALT BARRIER MUST BE INSTALLED OVER THE EXISTING SUBSTRATE TO FULLY SEPARATE THE JM EPDM FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.

DRAWING NO.

E-FW-M11

EPDM BASE & WALL FLASHING WITH COPING ISOMETRIC VIEW

NEW DETAIL

MEMBRANE TYPE:
JM EPDM

SCALE
N.T.S

ISSUE DATE
10-16-18

MAXIMUM GUARANTEE TERM:
N/A

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

