



## Evaluation Listing CCMC 13104-L AP™ Foil-Faced

<b>MasterFormat:</b>	07 21 13.07
<b>Evaluation issued:</b>	2003-04-17
<b>Re-evaluated:</b>	2018-09-13
<b>Revised:</b>	2019-08-29

### 1. Evaluation

The product conforms to CAN/ULC-S704-11. The product's classification, design long-term thermal resistance (LTTR) and water vapour permeance (WVP) values are provided in Table 1.1.

**Table 1.1 Specifications for Classification, Design LTTR and WVP of the Product**

Product	Classification	Design LTTR (m <sup>2</sup> °C/W)			25.4 mm WVP (ng/(Pa·s·m <sup>2</sup> ))
		Thickness			
		25 mm	50 mm	75 mm	
AP™ Foil-Faced	Type 1, Class 1	1.05	2.09	3.17	3.0

### 2. Description

The product is a rigid-board polyisocyanurate, thermal insulation. The product is faced as follows:

Product	Facing
AP™ Foil-Faced	foil/kraft paper on both sides

The product is manufactured in 1.2 m × 2.4 m, 1.2 m × 2.7 m and 1.2 m × 3 m panels that range from 12.5 mm to 114.3 mm thick.

### 3. Standard and Regulatory Information

See the Annex appended to this Listing, which summarizes the product standard.

This product was evaluated to the product standard referenced in the Annex current as of 2017-06-06. Note that the Annex may have been updated since this Listing was issued to include more recent editions of the applicable product standard. Therefore, this Listing may not reflect the requirements contained in any updated version of this product standard.

## Listing Holder

Johns Manville  
717 17th Street  
Denver, CO 80202-3330  
USA

**Telephone:** 303-978-2000

**Fax:** 303-978-2108

**Email:** [buildinginsulation@jm.com](mailto:buildinginsulation@jm.com)

**Web site:** [www.jm.com](http://www.jm.com)

## Plants

Cornwall, ON  
Femley, NV, USA

## Disclaimer

*This Listing is issued by the Canadian Construction Materials Centre, a program of the Construction Research Centre at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.*

*Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to [http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc\\_index.html](http://www.nrc-cnrc.gc.ca/eng/solutions/advisory/ccmc_index.html), or contact the Canadian Construction Materials Centre, Construction Research Centre, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone: 613-993-6189. Fax: 613-952-0268.*

*NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.*

**Date modified:**  
2019-09-04