

(SEE SECTION BELOW) SLIDE
FACEPLATE OVER SCUPPER SLEEVE

TOP HEM FILLED
WITH CAULK,
SEAL ALL SIDES
GALVANIZED METAL
FACE PLATE INSTALLED
OVER SCUPPER SLEEVE
PINNED & SEALED TO
EXTERIOR WALL

FACEPLATE ON
EXTERIOR WALL

TERMINATE TOP OF
BASE FLASHINGS
AS SPECIFIED

8" MIN. TO 24" MAX.
BASE FLASHING HT.

SMOOTH SBS TARGET
PATCH BEHIND
SCUPPER
ADHERED

DYNAFLEX
(EXTEND OVER
SCUPPER)

MASONRY WALL

SCUPPER SLEEVE
THROUGH WALL

ASPHALT PRIMER

JM FESCANT PLUS

3 COURSE ALL
EDGES OF OUTER
FLASHING AT SCUPPER
W/ MBR UTILITY CEMENT

SUMP CORNER

MITERED TAPERED
EDGE STRIPS
UNDER MEMBRANE

SET FLANGE INTO BED
OF MBR UTILITY CEMENT

NAIL FLANGE OF SCUPPER
THROUGH BASE FLASHING
AND ALL PLIES OF ROOF
INTO WOOD NAILER BELOW
WITH RING SHANK NAILS

WOOD NAILER SECURED TO
DECK UNDER SCUPPER FLANGE.
(SHOWN OUTSIDE OF
SUMP FOR CLARITY)

COVER BOARD

RIGID INSULATION

TOP PLY OF FIELD ROOFING
FESCO TAPERED EDGE STRIPS 0" x ___" THICK

JM APPROVED DECK

NOTES:

- ADHESIVE NOT SHOWN UNDER PLIES FOR CLARITY.
- PRIME ALL SCUPPER FLANGES ON BOTH SIDES WITH ASPHALT PRIMER.
- ALL SCUPPER FLANGES SHALL BE 4" WIDE. PLEASE REFER TO LOCAL CODES AND SMACNA FOR METAL SCUPPER AND CONDUCTOR HEAD FABRICATION REQUIREMENTS.
- REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
- SCUPPER FACEPLATE ON EXTERIOR SHOWN AS AN EXAMPLE.
- ANY CARPENTRY, METAL WORK, OR MASONRY CONSTRUCTION SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
- PLEASE SEE BITUMINOUS FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.

DRAWING NO.

DFE-21

DRAINS & VENTS

SCALE
N.T.S

ISSUE DATE
6-12-14

MEMBRANE TYPE:
BUR

MAXIMUM GUARANTEE TERM:

PRIMARY METAL SCUPPER IN SUMP

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

