

FACEPLATE ON EXTERIOR WALL

(SEE SECTION BELOW) SLIDE FACEPLATE OVER SCUPPER SLEEVE

TOP HEM FILLED WITH CAULK, SEAL ALL SIDES

GALVANIZED METAL FACE PLATE INSTALLED OVER SCUPPER SLEEVE PINNED & SEALED TO EXTERIOR WALL

TERMINATE TOP OF BASE FLASHINGS AS SPECIFIED

8" MIN. TO 24" MAX. BASE FLASHING HT.

SMOOTH SBS TARGET PATCH BEHIND SCUPPER ADHERED

DYNAFLEX (EXTEND OVER SCUPPER)

MASONRY WALL

SCUPPER SLEEVE THROUGH WALL

ASPHALT PRIMER

JM FESCANT PLUS

DYNAFLEX

3 COURSE ALL EDGES OF OUTER FLASHING AT SCUPPER W/ MBR UTILITY CEMENT

SOLDERED SCUPPER

SET FLANGE INTO BED OF MBR UTILITY CEMENT

NAIL FLANGE OF SCUPPER THROUGH BASE FLASHING AND ALL PLIES OF ROOF INTO WOOD NAILER BELOW WITH RING SHANK NAILS

WOOD NAILER SECURED TO DECK UNDER SCUPPER FLANGE. (SHOWN OUTSIDE OF SUMP FOR CLARITY)

TOP PLY OF FIELD ROOFING
COVER BOARD
RIGID INSULATION
JM APPROVED DECK

NOTES:

1. ADHESIVE NOT SHOWN UNDER PLIES FOR CLARITY.
2. SCUPPER FACEPLATE ON EXTERIOR SHOWN AS AN EXAMPLE.
3. PRIME ALL SCUPPER FLANGES ON BOTH SIDES WITH ASPHALT PRIMER.
4. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
5. ALL SCUPPER FLANGES SHALL BE 4" WIDE. PLEASE REFER TO LOCAL CODES AND SMACNA FOR METAL SCUPPER AND CONDUCTOR HEAD FABRICATION REQUIREMENTS.
6. ANY CARPENTRY, METAL WORK, OR MASONRY CONSTRUCTION SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
7. PLEASE SEE BITUMINOUS FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.

DRAWING NO.

DFE-22

DRAINS & VENTS

SCALE

N.T.S

ISSUE DATE

6-12-14

MEMBRANE TYPE:

BUR

MAXIMUM GUARANTEE TERM:

OVERFLOW METAL SCUPPER

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

