



JM PMMA MEMBRANE FLASHING SKIRT WRAPPED AROUND PENETRATION WITH MIN. 2" OVERLAP ALL JOINTS

ENSURE ALL MEMBRANE TERMINATIONS ARE ENCAPSULATED IN JM PMMA RESIN (TYP.)

JM PMMA PRIMER 1/8" MAX. ABOVE RESIN.

JM PMMA STANDARD RESIN COVERAGE 2" MAX. ABOVE PMMA SCRIM ALL AROUND-TYP.

THOROUGHLY CLEAN STEEL AND APPLY JM PMMA METAL PRIMER PRIOR TO INSTALLATION OF JM PMMA MEMBRANE FLASHING

ENSURE FULL RESIN SATURATION OF JM PMMA SCRIM AND CONTACT WITH SUBSTRATE

JM MEMBRANE FLASHING CONSISTING OF JM PMMA STANDARD RESIN, JM PMMA SCRIM, JM PMMA STANDARD RESIN

JM PMMA MEMBRANE COLLAR INSTALLED OVER PENETRATION WITH 1/4" MIN. VERTICAL UPTURN

BITUMINOUS FIELD MEMBRANE (CUT AWAY VIEW)

USE THIS DETAIL IN CONJUNCTION WITH DETAIL LB-FP-04S WHICH IS PART OF THIS INSTALLATION.

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE JM PMMA FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM PMMA MEMBRANE FLASHING CONSISTS OF JM PMMA STANDARD RESIN, JM PMMA SCRIM, JM PMMA STANDARD RESIN. USE THE APPROPRIATE JM PMMA PRIMER DEPENDING ON TYPE OF SUBSTRATE.

DRAWING NO.
LB-FP-04I

NEW DETAIL

SCALE
N.T.S

ISSUE DATE
6-18-18

WIDE FLANGE PENETRATION FLASHING

MEMBRANE TYPE:
JM PMMA OVER BITUMINOUS

MAXIMUM GUARANTEE TERM:
20 YEAR

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

