

JM PMMA MEMBRANE FLASHING SKIRT WRAPPED AROUND PENETRATION WITH MIN. 2" OVERLAP ALL JOINTS

ENSURE ALL MEMBRANE TERMINATIONS ARE ENCAPSULATED IN JM PMMA RESIN (TYP.)

JM PMMA PRIMER 1/8" MAX. ABOVE RESIN.
JM PMMA STANDARD RESIN COVERAGE 2" MAX. ABOVE PMMA SCRIM ALL AROUND-TYP.

8" (203 mm) RECOMMENDED

4" MIN. (102 mm)

JM PMMA MEMBRANE COLLAR INSTALLED OVER PENETRATION WITH 1/4" MIN. VERTICAL UPTURN

THOROUGHLY CLEAN STEEL AND APPLY JM PMMA METAL PRIMER PRIOR TO INSTALLATION OF JM PMMA MEMBRANE FLASHING

ENSURE FULL RESIN SATURATION OF JM PMMA SCRIM AND CONTACT WITH SUBSTRATE

JM MEMBRANE FLASHING CONSISTING OF JM PMMA STANDARD RESIN, JM PMMA SCRIM, JM PMMA STANDARD RESIN

JM PMMA FIELD MEMBRANE (CUT AWAY VIEW)

USE THIS DETAIL IN CONJUNCTION WITH DETAIL L-FP-04S WHICH IS PART OF THIS INSTALLATION.

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE JM PMMA FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM PMMA MEMBRANE FLASHING CONSISTS OF JM PMMA FLASHING RESIN, JM PMMA SCRIM, JM PMMA FLASHING RESIN. USE THE APPROPRIATE JM PMMA PRIMER DEPENDING ON TYPE OF SUBSTRATE.

DRAWING NO.

L-FP-04I

DRINS & VENTS

WIDE FLANGE PENETRATION FLASHING

MEMBRANE TYPE:
JM PMMA

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.

SCALE
N.T.S

ISSUE DATE
04-10-24

MAXIMUM GUARANTEE TERM:
20 YEAR

