


ISOMETRIC VIEW

- JM EPDM PEEL & STICK WALKPAD-SEE NOTE 4
- JM EPDM TAPE PRIMER-SEE NOTE 3
- JM EPDM MEMBRANE ADHERED, BALLASTED OR MECHANICALLY FASTENED
- JM EPDM MEMBRANE ADHESIVE (FOR ADHERED SPECIFICATIONS ONLY)

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST CURRENT INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC) MUST BE APPLIED ON ALL SURFACES COMING INTO CONTACT WITH JM EPDM PEEL & STICK PRODUCTS. ROLL MEMBRANE WITH A HAND ROLLER UNDER PRESSURE AT SEAM IN ACCORDANCE WITH THE JM INSTALLATION GUIDE. JM EPDM WALKPADS HAVE THREE ROWS OF FACTORY APPLIED TAPE.
4. ROLL OVER INSTALLED WALKPADS WITH A WEIGHTED ROLLER TO ENSURE PROPER ADHESION.
5. ON MECHANICALLY FASTENED SYSTEMS AVOID INSTALLING WALKPADS OVER FASTENER PLATES WHENEVER POSSIBLE.
6. 1/8" TO 1/4" OF JM EPDM SEAM TAPE MUST BE EXPOSED ALONG ENTIRE LENGTH OF ALL SEAMS.
8. DO NOT INSTALL WALKPADS OVER MEMBRANE SEAMS.

DRAWING NO. E-PT-05		EPDM PEEL & STICK WALKPADS OVER EPDM MEMBRANE		
NEW DETAIL		MEMBRANE TYPE: JM EPDM	<small>Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.</small>	
SCALE N.T.S	ISSUE DATE 7-10-17	MAXIMUM GUARANTEE TERM: 30 YEAR		