

ROLL PATCHES INTO SEAMS WITH
HAND ROLLER UNDER PRESSURE
AND CREASE INTO SEAMS
ACCORDING TO THE JM EPDM
APPLICATION GUIDE

12" x 12"
(304 mm X 304 mm)
PATCH CUT FROM
JM EPDM 12"
PEEL & STICK FLASHING

JM 6" EPDM
SEALING STRIP

JM EPDM 3" SEAM
TAPE-EXPOSE 1/8" TO 1/4"

JM EPDM F.I.T. MEMBRANE
WITH 4" FACTORY IN-SEAM
TAPE ADHERED

JM EPDM TAPE PRIMER
SEE NOTE 5

JM 6" EPDM
SEALING STRIP

JM SINGLE PLY LVOC CAULK ALL
AROUND PEEL & STICK FLASHING

JM 6" EPDM SEALING STRIP

JM SINGLE PLY PRIMER
SEE NOTE 5

ISOMETRIC VIEW

JM EPDM MEMBRANE

JM EPDM MEMBRANE
ADHESIVE

JM INSULATION / COVER BOARD

APPROVED DECK

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE (www.jm.com) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECIFICATIONS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. ON DAYS WITH TEMPERATURES GREATER THAN 85° WHERE SHEETS ARE ALIGNED PRIOR TO RELAXING, OVERLAP SHALL BE 5" FOR 6" SEAM TAPE AND 3" FOR 4" SEAM TAPE TO ALLOW FOR PROPER SEAM ENGAGEMENT.
5. JM EPDM TAPE PRIMER OR JM SINGLE PLY MEMBRANE PRIMER (LOW VOC) MUST BE APPLIED ON ALL SURFACES COMING INTO CONTACT WITH JM EPDM PEEL & STICK PRODUCTS.
ROLL MEMBRANE WITH HAND ROLLER UNDER PRESSURE AT SEAM IN ACCORDANCE WITH THE JM EPDM INSTALLATION GUIDE.

DRAWING NO.

E-MS-PT4

MEMBRANE SEAMING

EPDM TAPE / STANDARD SHEET SIDE LAP & T-JOINT 30 YEAR

MEMBRANE TYPE:
JM EPDM

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy for general educational purposes only. This complimentary assistance is not to be either used or relied upon by anyone as a substitute for professional engineering design and documentation required by any building code, contract, or applicable law. By accepting the general conceptual information, you agree it does not constitute any representations, endorsements of, or an assumption by Johns Manville of any duty or liability for either the adequacy of the design of a building, any of its components or the sufficiency of any construction.

SCALE
N.T.S

ISSUE DATE
08-24-20

MAXIMUM GUARANTEE TERM:
30 YEAR

