



APPROPRIATE VERTICAL JM FASTENERS 12" (304 mm) O.C. MAX. REQUIRED FOR WALLS GREATER THAN 5 FT. IN HEIGHT


STEP 1



APPROVED WALL / SUBSTRATE

1 1/2" (38 mm) MINIMUM CONTINUOUS WELD

STEP 3 AT INSIDE CORNER



FOLD AND WELD SIMILAR TO THIS

JM TPO UNIVERSAL CORNER WELDED TO FLASHING SHEET (FOLDED AS SHOWN)


PLAN VIEW OF FLASHING "B"

90° BEND IN FLASHING

STEP 2

TPO MEMBRANE ADHESIVE BETWEEN OVERLAP (NOT SHOWN)

INCISE & CUT OUT TPO FLASHING AND POSITION AS SHOWN



JM APPROVED FASTENER AND PLATE PENETRATION DEPENDANT ON DECK MATERIAL(S). SEE SPECIFICATIONS FOR FURTHER INFORMATION

APPROVED WALL / SUBSTRATE

JM TPO EDGE SEALANT IF REQUIRED

NOTES:

1. REFER TO JOHNS MANVILLE WEBSITE ([www.jm.com](http://www.jm.com)) FOR MOST UP-TO-DATE INFORMATION.
2. PLEASE SEE SINGLE PLY FLASHING SPECIFICATIONS FOR A FULL DESCRIPTION OF INSTALLATION INSTRUCTIONS AND REQUIREMENTS WHICH ARE CONSIDERED A PART OF THIS DETAIL.
3. ANY CARPENTRY OR METAL WORK SHOULD BE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LOCAL CODE REQUIREMENTS AND/OR PROJECT SPECS. THESE COMPONENTS SHOULD BE REVIEWED AND APPROVED BY A LICENSED DESIGN PROFESSIONAL.
4. JM TPO EDGE SEALANT IS REQUIRED ON ALL CUT OR NON ENCAPSULATED EDGES OF REINFORCED MEMBRANE. THIS INCLUDES FACTORY CUT EDGES (SEE DETAIL T-MS-01).

DRAWING NO.

INSIDE CORNER

T-FC-04

CURB & CORNER

MEMBRANE TYPE:  
JM TPO

SCALE  
N.T.S

ISSUE DATE  
03-15-19

MAXIMUM GUARANTEE TERM:  
30 YEAR

Johns Manville is a manufacturer of commercial roofing products and offers this general conceptual information to you as a courtesy. This complimentary assistance is not to be used or relied upon by anyone as a substitute for professional engineering design and documentation required by building code, contract, or applicable law. By accepting these comments you agree they do not constitute any representations, endorsements of, or an assumption by Johns Manville of any liability for either the adequacy of the design of this building or any other material not supplied by Johns Manville.

