

SUGGESTED LENGTH OF CUT OR STRETCH-OUT FOR JACKETING

Pipe Size		Total Nominal Thickness of Pipe Insulation - in. (mm)						
		1(25)	1½ (38)	2(51)	2½ (64)	3(76)	3½ (89)	4(102)
in.	mm	Length of Cut for Sheet Metal Thickness - in.						
½	15	12¼	16	19	24	27¼	30½	33½
¾	20	12¼	16	19	24	27¼	30½	33½
1	25	14¼	17 ½	20¾	24¼	27¼	30½	33½
1¼	32	14¼	19	20¾	24¼	27¼	30½	33½
1 ½	40	16	19	24¼	27¼	30½	33½	37
2	50	17 ½	20¾	24¼	27¼	30½	33½	37
2 ½	65	19	24¼	27¼	30½	33¾	37	40¼
3	80	21	24¼	27¼	30½	33¾	37	40¼
3½	90	24	27¼	30½	33¾	37¼	40¼	43½
4	100	24¼	27¼	30½	33¾	37¼	40¼	43½
4 ½	115	27¼	30½	33½	37	40¼	43½	47½
5	125	27¼	30½	33½	37	40¼	43½	47½
6	150	30 ½	33½	37	40¼	43¼	47½	50½
7	175	33 ½	37	40¼	43½	47½	50½	53¾
8	200	-	40¼	43½	47½	50½	53¾	57
9	225	-	43½	47½	50½	53¾	57	60¼
10	250	-	47½	50½	53¾	57	60¼	63¼
11	275	-	50½	53¾	57	60	63¼	66½
12	300	-	53¾	57	60¼	63¼	66½	69¾
14	350	-	57	60¼	63¼	66½	69¾	72¾
15	375	-	60¼	63¼	66½	69¾	72¾	76
16	400	-	63¼	66½	69¾	72¾	76	79¼*
17	425	-	66½	69¾	72¾	76	79¼*	82¼*
18	450	-	69¾	72¾	76	79¼	82¼*	85½*
19	475	-	72¾	76	79	82¼	85½*	88½*
20	500	-	76	79¼	82½	85½	88½*	92*
21	525	-	79	82¼	85¼	88½	91½*	95*
22	550	-	82½	85½	88½	92	95¼*	97½*
23	575	-	85¼	88½	91¼	95	97½*	-
24	600	-	88½	92	95	98¼	-	-

Length of cut based on 3" (76 mm) longitudinal lap.

Length of cut are to the nearest ¼" (6 mm) with allowance for manufacturer's tolerance in thickness of pipe insulation.

* These dimensions are for single layer pipe insulation only.

INDUSTRIAL INSULATION
THERMO-1200®
CALCIUM SILICATE PIPE INSULATION
STRETCH-OUT TABLE FOR JACKETING

QUALITY STATEMENT

Johns Manville products are designed, manufactured and tested to strict quality standards in our own facilities. This along with third party auditing is your assurance that this product delivers consistent high quality.

ISO 9001 CERTIFICATION

Thermo-1200 is manufactured and tested in our own facility under an implemented Quality Management System which is certified to be in accordance with ISO 9001 quality standards.

PRODUCT CERTIFICATION

When ordering material to comply with any government specification or any other listed specification, a statement of that fact must appear on the purchase order. Government regulations and other listed specifications require specific lot testing, and prohibit the certification of compliance after shipment has been made. There may be additional charges associated with specification compliance testing. Please refer to IND-CSP-3 for Certification Procedures and Charges. Call customer service for more information (1-800-866-3234).



717 17th St.
Denver, CO 80202
800-866-3234
JM.com

Technical specifications as shown in this literature are intended to be used as general guidelines only. Please refer to the Safety Data Sheet and product label prior to using this product. The physical and chemical properties of the MinWool-1200® listed herein represent typical, average values obtained in accordance with accepted test methods and are subject to normal manufacturing variations. They are supplied as a technical service and are subject to change without notice. Any references to numerical flame spread or smoke developed ratings are not intended to reflect hazards presented by these or any other materials under actual fire conditions. Check with the Regional Sales Office nearest you for current information.

All Johns Manville products are sold subject to Johns Manville's standard Terms and Conditions, which includes a Limited Warranty and Limitation of Remedy. For a copy of the Johns Manville standard Terms and Conditions or for information on other Johns Manville thermal insulation and systems, visit www.jm.com/terms-conditions or call (800)654-3103.